



BUREAU OF WEIGHTS & MEASURES

PO Box 8911

Madison, WI 53708

608-224-4942

[datcpweightsandmeasures](mailto:datcpweightsandmeasures@wisconsin.gov)

@wisconsin.gov

www.datcp.wi.gov

RESOURCES

More information on applicable Wisconsin laws can be found at these links:

Wis. Admin. Code §ATCP 93.510

https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/510

Wis. Admin Code § ATCP 93.515

https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/515

Materials Approval Page

https://datcp.wi.gov/Pages/Programs_Services/MaterialApprovalsLeakDetection.aspx

Veeder-Root

<http://www.veeder.com/us/>

Approval #20130002

<https://datcp.wi.gov/Documents/TCP-WM-MA-20130002.pdf>

Leak Detection Test Reporting Requirements for Veeder-Root ATG Interstitial Monitoring Leak Detection for the TLS-450 model

When to submit your test results

- When renewing your annual Permit-to-Operate the owner/operator must supply the department with passing test reports of the 3 most current consecutive months of testing, and each test must be 28-32 days apart. For example, if your first test was June 1, the second test must be July 1, and the third test must be on August 1.
- When an inspection is conducted by the State of Wisconsin, at least 12 months of test reports must be available for review by a state inspector.
- Below is the Interstitial Monitoring test report example that the Veeder-Root TLS-450 ATG system will print. You are required to submit the test report when renewing your annual permit to operate.

SEP 1, 2015 5:00 AM

BUSINESS NAME

ADDRESS

CITY

STATE, ZIP CODE

LIQUID STATUS REPORT

SENSOR	LOCATION	STATUS
L 1	UNLEADED INTERSTITIAL	NORMAL
L 2	DIESEL INTERSTITIAL	NORMAL

SEP 1, 2015 5:01 AM

BUSINESS NAME

ADDRESS

CITY

STATE, ZIP CODE

SENSOR STATUS REPORT - ALL SENSORS

#	SENSOR LOCATION	STATUS
L 1	UNLEADED INTERSTITIAL	NORMAL
L 2	DIESEL INTERSTITIAL	NORMAL

If you have questions about how your Veeder-Root ATG system works please contact your service company or [Veeder-Root](http://www.veeder.com/us/) directly. You can also find further information about your specific leak detection equipment on the materials approval page of our [website](https://datcp.wi.gov/Pages/Programs_Services/MaterialApprovalsLeakDetection.aspx). The Veeder-Root material approval number is [20130002](https://datcp.wi.gov/Documents/TCP-WM-MA-20130002.pdf).

(over)

Leak detection FAQs:

- *What is leak detection?*
“Leak Detection” means determining whether a discharge of regulated substance has occurred from a storage tank system into the environment or into the space between the tank and its secondary barrier or containment.
- *What is “ATG”?*
“Automatic Tank Gauging” (ATG) or “Automatic Leak Detection” means a leak detection or monitoring system that will provide continuous 24-hour monitoring for the detection of a release or leak of vapor or product and will immediately communicate the detection of the release or leak to an electronic signaling device.
- *What is Interstitial Monitoring?*
[Wisconsin Administrative Code §§ ATCP 93.510](#) and [93.515](#) require all new and existing underground tank systems which store regulated substances to be provided with a method of leak detection. One of the acceptable methods of leak detection is “Interstitial Monitoring”.

Interstitial monitoring is a leak detection method that entails the surveillance of the space between a tank system’s walls and the secondary containment system, for a change in the steady-state conditions.

Rev. 11/17/16